



DTN Engineering  
2731 K Street Unit A  
Eureka, CA 95501  
Ph: (916) 215-7769  
Email: dnicoletti@dtngineering.com

Date: August 4, 2023

RE: Electrical Load Calculations for Nina Star Farms APN -14-006-16.

DTN Engineering evaluated the electrical loads for the proposed development at 23180 Shady Grove Rd Middletown, CA, 95461. These electrical loads have been developed based off an industry standard equipment layout, which is in accordance with the Nina Star Farms site map and operations plan.

The electrical loads for Nina Star Farms is proposed to be 3300 amps. The 3300 amps. Reflect a 20% load reduction as allowed in the 2022 version of the California Electrical Code.

If you have any questions or concerns, please feel free to reach out.

Thank you!

David Nicoletti PE

